


# CERTIFICATE

Certified Passive House Component

Component-ID 1089wi04 valid until 31st December 2024

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany




Category: **Window Frame**  
Manufacturer: **Industrias REHAU,  
Gavá,  
Spain**  
Product name: **SYNEGO**

**This certificate was awarded based on the following  
criteria for the warm, temperate climate zone**

Comfort  $U_W = 1.00 \leq 1.00 \text{ W}/(\text{m}^2 \cdot \text{K})$   
 $U_{W,\text{installed}} \leq 1.05 \text{ W}/(\text{m}^2 \cdot \text{K})$   
with  $U_g = 0.90 \text{ W}/(\text{m}^2 \cdot \text{K})$

Hygiene  $f_{Rsi=0.25} \geq 0.65$



Passive House  
efficiency class

phE

phD

phC

phB

phA


[www.passivehouse.com](http://www.passivehouse.com)

warm, temperate climate



**CERTIFIED  
COMPONENT**

Passive House Institute



Calculation model Isothermal

**Description**

PVC-frame with steel-reinforcements and insulation (0.031 W/(mK)) inside the main-frame. Pane thickness: 48 mm (4/18/4/18/4), rebate depth: 19 mm. Spacer: SWISSPACER Ultimate.

**Explanation**

The window U-values were calculated for the test window size of 1.23 m × 1.48 m with  $U_g = 0.90 \text{ W}/(\text{m}^2 \cdot \text{K})$ . If a higher quality glazing is used, the window U-values will improve as follows:




Glazing	$U_g =$	0.90	0.70	0.68	0.64	$\text{W}/(\text{m}^2 \cdot \text{K})$
		↓	↓	↓	↓	
Window	$U_W =$	1.00	0.87	0.85	0.83	$\text{W}/(\text{m}^2 \cdot \text{K})$






Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on [www.passivehouse.com](http://www.passivehouse.com) and [passipedia.org](http://passipedia.org).

## Validated installations

Exterior insulation and finishing system		Lightweight timber (operable)		Cavity wall	
$U_{Wall} = 0.22 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{Wall} = 0.20 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{Wall} = 0.22 \text{ W}/(\text{m}^2 \cdot \text{K})$	
					
$\Psi_{install}$	W/(m · K)	$\Psi_{install}$	W/(m · K)	$\Psi_{install}$	W/(m · K)
Top	0.006	Top	0.012	Top	0.009
Side	0.006	Side	0.012	Side	0.009
Bottom	0.033	Bottom	0.032	Bottom	0.044
$U_{W,installed} = 1.04 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{W,installed} = 1.05 \text{ W}/(\text{m}^2 \cdot \text{K})$		$U_{W,installed} = 1.05 \text{ W}/(\text{m}^2 \cdot \text{K})$	

Frame values			Frame width $b_f$ mm	$U$ -value frame $U_f$ W/(m <sup>2</sup> · K)	$\Psi$ -glazing edge $\Psi_g$ W/(m · K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Mullion 1 casement	(1M1)		164	1.12	0.027	0.58
Flying Mullion	(FM1)		164	1.05	0.027	0.61
Bottom	(OB1)		117	1.03	0.026	0.72
Top	(OH1)		117	1.03	0.026	0.72
Lateral	(OJ1)		117	1.03	0.026	0.72
Spacer: SWISSPACER Ultimate				Secondary seal: Polysulfide		

